Lead

Lead have action levels instead of MCLs. An action level is exceeded when
the concentration in more than 10 percent of tap water samples collected during
a monitoring period exceeds the action level.

The Lead Action Level is 0.015 mg/L

As you can see in the chart below Patton Borough Water Department meets these requirements and is in compliance with the 90th Percentile requirement.

Lead 90th Percentile Chart – June 2018

Sample	Test		Result	Units
1806322-010	Lead	10th Sample, 90th Percentile	<0.005	mg/L
1806322-009	Lead	9	<0.005	mg/L
1806322-008	Lead	8	<0.005	mg/L
1806322-007	Lead	7	<0.005	mg/L
1806322-006	Lead	6	<0.005	mg/L
1806322-005	Lead	5	<0.005	mg/L
1806322-004	Lead	4	<0.005	mg/L
1806322-003	Lead	3	<0.005	mg/L
1806322-002	Lead	2	<0.005	mg/L

1806322-001	Lead	1	<0.005	mg/L

For More Information

You may contact Ken Trinkley, Water Manager at (814) 674-3653 or the DEP Cambria Office at (814) 472-1900. For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's website at: www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.