

CARDAN LABORATORIES, INC.  
PO BOX 541  
634 14TH STREET  
NORTHERN CAMBRIA, PA 15714-0541  
PH: 814-948-8650 FAX: 814-948-5893  
Coal, Water, Gas, Rock, Dust, Mine Air, Etc.  
DEP CERTIFICATION 11-139

05/31/2019

PATTON BORO  
P.O. BOX 175  
PATTON, PA 16668

LABORATORY NUMBER: 7277

SOURCE: 603 MAGEE AVE. ID 703

SAMPLED BY: KRT      DATE SAMPLED: 05/29/2019 09:00  
DATE REC'D...: 05/29/2019 11:50

B A C T E R I O L O G I C A L   E X A M I N A T I O N

DATE STARTED: 05/29/2019 15:05      ANALYST: SS  
DATE ENDED...: 05/30/2019 15:05      ANALYST: SS

METHOD: SM9223B

\* \* \* \* \* R E S U L T S \* \* \* \* \*

	DATE	TIME	ANALYST
TOTAL COLIFORM: ABSENT	05/30/2019	15:05	SS
E-COLI.....: ABSENT	05/30/2019	15:05	SS

THIS TEST HAS INDICATED THAT THIS WATER IS ACCEPTABLE.

No problems were encountered during analysis of this workorder,  
except if noted in this report.

CARDAN LABORATORIES, INC.

BY: 